

DECLARATION OF CONFORMITY

The Company : TECNOCONTROL S.r.l. with legal office in GUSSAGO (BS) Via Enrico Fermi n. 98.
declare under its sole responsibility that the products for boilers methane and LPG:

- Central Unit with one sensor: SE126KG – SE126KM
- Central Unit with one remote sensor: SE127K – SE128K – SE139K
- Central Unit with three remote sensors: SE184K – SE194K
- Sensors for central units: SE192KG – SE192KM – SE193KG – SE193KM

which this declaration refers to, have been designed and manufactured in accordance with the following normative / other normative documents / specifications where applicable:

The products have been approved in the typical configuration of installation and with peripherals in conformity to EMC directive.

1) *LOW TENSION directive 2006/95 CEE (no Atex)*

- EN 50194 : Electric devices for detection and measure of flammable gas **for domestic use**. General ordinances and test methods
- EN 50244 : Electric devices for detection and measure of flammable gas **for domestic use**. Test methods and performances descriptions.
- EN 61779-1: Electric devices for detection and measure of flammable gas. Test methods and performances descriptions.
- EN 61779-4: Regulations about performances of Group II devices which indicate up to 100% LEL of gas.
- EN 50073: Guide for the choice, installation, use and maintenance of electric devices for detection and measure of flammable gas or oxygen.

ELECTROMAGNETIC COMPATIBILITY directive 89/336CEE

- EN 50081-1 : Electromagnetic compatibility Generic ordinance on the emission - Part 1 : domestic, commercial and industrial environments.
- EN 50082-1 : Electromagnetic compatibility Generic ordinance on the immunity - Part 1 : domestic, commercial and industrial environments.

GUSSAGO , date 6st June 2007

MOD 17-01 rev.1




G.P. CAVAGNA
General Manager