

AENOR

Certificate of constancy of performance

CE

0099

0099/CPR/A70/0057

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

AGUILERA EXTINCION, S.L.

registered office CL JULIÁN CAMARILLO, 26 28037 MADRID (España)

Construction Product Check valves and non-return valves

Harmonized Standard EN 12094-13:2001
EN 12094-13:2001/AC:2002


References Specified in Annex to the Certificate

Production site PI FIN DE SEMANA, AV. ALONSO PEÑA BOEUF, 6 28022 MADRID (España)

Certification scheme This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonized standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2010-04-14
Last issued 2017-04-14
Validity date 2018-04-14



Avelino BRITO
General Manager

Original Electrónico

AENOR

Certificate of constancy of performance

0099/CPR/A70/0057

Annex to Certificate

Type of valve	Trade mark	References	Nominal diameter	Working pressure	Gases allowed
Check	AGUILERA EXTINCIÓN	AEX/VAR112	1 1/2"	140 for CO2 137 for HFC 23 53 for HFC 227 ea 47 for FK-5-1-12 60 for IG-01 60 for IG-55 60 for IG-100 60 for IG-541	CO2 HFC 23 HFC 227 ea FK-5-1-12 IG-01 IG-55 IG-100 IG-541
Check	AGUILERA EXTINCIÓN	AEX/VAR114	1 1/4"	140 for CO2 137 for HFC 23 53 for HFC 227 ea 47 for FK-5-1-12 60 for IG-01 60 for IG-55 60 for IG-100 60 for IG-541	CO2 HFC 23 HFC 227 ea FK-5-1-12 IG-01 IG-55 IG-100 IG-541
Check	AGUILERA EXTINCIÓN	AEX/VAR12	1/2"	140 for CO2 137 for HFC 23 53 for HFC 227 ea 47 for FK-5-1-12 60 for IG-01 60 for IG-55 60 for IG-100 60 for IG-541	CO2 HFC 23 HFC 227 ea FK-5-1-12 IG-01 IG-55 IG-100 IG-541

First issued on 2010-04-14
Last issued 2017-04-14
Validity date 2018-04-14

Original Electrónico

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Authorized control body accredited by ENAC. Accreditation number: OC-P/137