



## Certificate of constancy of performance

0099/CPR/B85/0129

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

### AGUILERA ELECTRONICA, S.L.

registered office CL JULIAN CAMARILLO, 26 2º PTA.  
28037 MADRID (Spain)

Certified performance **Reaction to Fire of power electric cables for general applications in construction Works.**

Harmonised Standard EN 50575:2014  
EN 50575:2014/A1:2016

Designation S01Z1  
Trade Mark AGUILERA AE/MANG2RF30C  
Reaction to Fire Class Cca-s1b,d1,a1  
Cross-sectional Range 2x1,5 mm<sup>2</sup>  
Rated Voltage 300/500 V  
Generic Power Cable Family Multicore sheathed (unarmoured)

Production site Code 659364

Certification scheme This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonised standard are applied.  
This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2017-07-06  
Last issued on 2023-06-21  
Validity 2026-06-21

Rafael GARCÍA MEIRO  
CEO

