

AENOR

Certificate of constancy of performance

CE
0099

0099/CPR/B85/0131

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

AGUILERA ELECTRONICA, S.L.

registered office	CL JULIAN CAMARILLO, 26 2º PTA. 28037 MADRID (España)
Certified performance	Reaction to Fire of power electric cables for general applications in construction Works.
Harmonized Standard	EN 50575:2014 EN 50575:2014/A1:2016
Designation	Z10Z1
Trade Mark	AGUILERA AE/MANG485ROH
Reaction to Fire Class	Cca-s1b,d1,a1
Cross-sectional Range	3x0,5 mm ²
Rated Voltage	300/500 V
Production site	Code 659364
Certification scheme	This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonized standard are applied. This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.
First issued on	2017-07-07
Validity date	2020-07-07

Rafael GARCÍA
General Manager