



EVPÚ[®]

NOTIFIED BODY No. 1293

EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0125
of February 19, 2009

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Conventional Fire Alarm Control Panel AE/C5-8-16

it receives and evaluates signals from detectors, signaling and transmitting informations about it's actual position, and it controls fire detection and fire alarm systems connecting equipments, servient to limiting of fire extension; is intended for power supply of control and indicating equipment and has declared a compatibility with it

placed on the market by

AGUILERA ELECTRONICA, S.L.U.
26, Julian Camarillo, 28037 Madrid, Spain

and produced in the factory

VAT No. BG130529900

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPÚ a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

EN 54-2: 1997 + AC: 1999/A1: 2006

EN 54-4: 1997 + AC: 1999/A1: 2002

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on February 19, 2009 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Karol Glamoš



016822

Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.