



Certificate of constancy of performance

0099/CPR/B85/0132

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

AGUILERA ELECTRONICA, S.L.

registered office CL JULIAN CAMARILLO, 26 2º PTA.
28037 MADRID (España)

Certified performance **Reaction to Fire of power electric cables for general applications in construction Works.**

Harmonised Standard EN 50575:2014
EN 50575:2014/A1:2016

Designation Z1Z1
Trade Mark AGUILERA AE/MANG3ROH
AGUILERA AE/MANG4ROH

Reaction to Fire Class Cca-s1b,d1,a1


See annex for more information.

Production site Code 659364

Certification scheme This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonised standard are applied.
This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2017-07-06
Last issued on 2023-06-21
Validity 2026-06-21

Rafael GARCÍA MEIRO
CEO





Certificate of constancy of performance

0099/CPR/B85/0132

Annex to Certificate

Designation Z1Z1
Reaction to Fire Class Cca-s1b,d1,a1

Trade Mark	Cross-sectional Range	Rated Voltage	Generic Power Cable Family
AGUILERA AE/MANG3ROH	2x1,5 mm ² + 1x0,75 mm ²	300/500 V	Multicore sheathed (unarmoured)
AGUILERA AE/MANG4ROH	2x2,5 mm ² + 2x0,50 mm ²	300/500 V	Multicore sheathed (unarmoured)

First issued on 2017-07-06
Last issued on 2023-06-21
Validity 2026-06-21



AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com