


Loss Prevention Certification Board



This is to certify

COOPER FULLEON LIMITED

Llantarnam Park, Cwmbran, South Wales, NP44 3AW

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

CX and CXL range of manual call points
(refer to attached appendix for details)

which have complied with the requirements of the following:

EN 54-11: 2001 – Fire detection and fire alarm systems - Manual call points

Certificate No. 378c


Issue No. 08

Date of Issue 10 March 2009

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB


Name: P STEVENS



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 378c

COOPER FULLEON LIMITED

Products		LPCB Ref. No.
CX/G/R/NB	Conventional re-settable indoor manual call point, flush mounted Note: 1: Approved with V4NCSET7 Mk1 or V4NSET7-UL micro switches only.	378c/01
CX/G/R/BB	Conventional re-settable indoor manual call point, with surface mount back box Note: 1: Approved with V4NCSET7 Mk1 or V4NSET7-UL micro switches only.	378c/01
CX/P/R/NB	Conventional indoor manual call point, flush mounted Note: 1: Approved with V4NCSET7 Mk1 or V4NSET7-UL micro switches only.	378c/02
CX/P/R/BB	Conventional indoor manual call point, with surface mount back box Note: 1: Approved with V4NCSET7 Mk1 or V4NSET7-UL micro switches only.	378c/02
CXL/GP/R/BB	Conventional type A glass or plastic re-settable indoor manual call point, with surface mount back box	378c/03
CXL/GP/R/NB	Conventional type A glass or plastic re-settable indoor manual call point, flush mounted	378c/03
CXL/GP/R/WP	Conventional type A glass or plastic re-settable indoor/outdoor manual call point	378c/04
CXL/GP/R/BB	Conventional type A glass or plastic re-settable indoor manual call point, with surface mount back box	378c/05
CXL/GP/R/NB	Conventional type A glass or plastic re-settable indoor manual call point, flush mounted	378c/05
CXL/GP/R/WP	Conventional type A glass or plastic re-settable indoor/outdoor manual call point	378c/06

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: P STEVENS

Page 2 of 3


Date of Issue 10 March 2009

Issue No. 08

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 378c

COOPER FULLEON LIMITED

Products

LPCB Ref. No.

CXL/GP/R/BB/HE	Conventional Type A glass or plastic re-settable indoor manual call point with Chinese text	378c/07
CXL/GP/R/WP/HE	Conventional Type A glass or plastic re-settable indoor / outdoor manual call point with Chinese text	378c/08

Accessories

/BB surface mounted (plastic back box)

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: P STEVENS

Page 3 of 3

Date of Issue 10 March 2009

Issue No. 08

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.