

Declaration of performance

№ 075/2016

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

**MAG4P (Fire Line MAG4P, AE/C5-4P); MAG4 (Fire Line MAG4, AE/C5-4M);
MAG2P (Fire Line MAG2P, AE/C5-2P); MAG2 (Fire Line MAG2, AE/C5-2M)**

2. *Type Number:*

**MAG4P (Fire Line MAG4P, AE/C5-4P); MAG4 (Fire Line MAG4, AE/C5-4M);
MAG2P (Fire Line MAG2P, AE/C5-2P); MAG2 (Fire Line MAG2, AE/C5-2M)**

Description:

Conventional Fire Alarm Control Panel

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

Fire detection and fire alarm systems installed in and around buildings

4. *Manufacturer*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

5. *Trading Company*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

6. *System of assessment*

System 1

7. *Notified Body*

**EVPU a.s.
19 Trencianska Str.
018 51 Nova Dubnica, Slovakia**

Notified Body Number

1293

EC Certificate Number

1293- CPR-0510

8. *No European Technical Assessment has been issued for this product.*

9. Declared performance

Essential characteristics	Performance	Harmonized technical specification EN 54-2:1997 + AC:1999 + A1:2006
Performance under fire conditions	Pass	4, 5, 7
Response delay (response time to fire)	Pass	7.1, 7.7, 7.11, 7.12
Operational reliability	Pass	4, 5, 6, 7, 8, 9, 10,11,12,13,14
Durability of operational reliability, Temperature resistance	Pass	15.4
Durability of operational reliability, Vibration resistance	Pass	15.6, 15.7, 15.15
Durability of operational reliability, Electrical stability	Pass	15.8-15.13
Durability of operational reliability: humidity resistance	Pass	15.5, 15.14

Essential characteristics	Performance	Harmonized technical specification EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Performance of power supply	Pass	4, 5, 6
Operational reliability	Pass	4, 5, 6, 7, 8
Durability of operational reliability, Temperature resistance	Pass	9.5
Durability of operational reliability, Vibration resistance	Pass	9.7, 9.8, 9.15
Durability of operational reliability, Electrical stability	Pass	9.9-9.13
Durability of operational reliability: humidity resistance	Pass	9.6, 9.14

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1407 Sofia,
14A, Srebarna Str.
27.06.2017

Yuliy Iliev
Quality Manager

