

## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 14A, Srebarna Str.  
1407 Sofia, Bulgaria

*Declares that the*

**Product:** MAG8  
**Description:** Conventional Fire Alarm Control Panel

*Complies to the following standards:*

EN 54-2:1997/A1:2006  
EN 54-4:1997/A2:2006  
EN 60950-1:2006+A11:2009+A12:2011+A1:2010+A2:2013  
EN 55032:2015  
EN 61000-3-2:2006+A1:2009+A2:2009  
EN 61000-3-3:2008

*The following Regulation:*

CPR № 305/2011  
REACH No 1907/2006

*And the following Directives:*

2014/30/EU - EMC  
2014/35/EU - LVD  
2011/65/EU – RoHS II

**Additional information:**

**First date of production:** 10.2011

**Certificate:**

№ 1293 – CPR –0542 of April 11, 2017 from Notified body № 1293 EVPU

**Test Report:**

№ 00096/2013/C of June 14, 2013 from Notified body № 1293 EVPU

1407 Sofia,  
14A, Srebarna Str.  
28.06.2017

Yuliy Iliev  
Quality Manager

