DECLARATION OF PERFORMANCE

European Safety Systems Ltd. Manufacturer: Impress House, Mansell Road, Acton

London, W3 7QH, UK

Intended Use: Fire Safety (Fire Detection and Fire Alarm Systems - Alarm

IS-mA1

Devices - Sounders, buildings)

System of Assessment and

Verification of Constancy of Performance:

Notified Body for EC type Examination and Factory

VdS Schadensverhütung GmbH

Notified Body No.: 0786

Amsterdamer Str 172-174, 50735 Köln, Germany

EC-type Examination Certificate: 0786-CPD-20338

Standards: EN 54-3:2001 / A1:2002 / A2:2006

Declared Performance:

Production Control:

Equipment Type:

Essential Characteristics	Performance	Standard
Performance parameters under fire conditions		EN 54-3:2001 / A1:2002 / A2:2006
- Sound level	Pass	Clause 4.2
- Frequencies and sound pattern	Pass	Clause 4.3
- Reproducibility	Pass	Clause 5.2
- Operational Performance	Pass	Clause 5.3
Attention drawing signal and message broadcast	Not applicable	Clause C.3.1
sequences		0.0000 0.0.1
- Synchronisation	Not applicable	Clause C.3.2
- Broadcast message performance	Not applicable	Clause C.5.1
Attention drawing signal/silence/message sequence	Not applicable	Clause C.5.2
timing	. 101 app 0 a 5. 0	0.0000 0.0.2
Message synchronisation testing	Not applicable	Clause C.5.3
<u> </u>		
Operational reliability		EN 54-3:2001 / A1:2002 / A2:2006
- Durability	Pass	Clause 4.4
- Construction	Pass	Clause 4.5
- Marking and data	Pass	Clause 4.6
- Durability	Pass	Clause 5.4
- General testing	Not applicable	Clause C.4
Durability of operational reliability, temperature resistance		EN 54-3:2001 / A1:2002 / A2:2006
- Dry heat (operational)	Pass	Clause 5.5
- Dry heat (endurance)	Pass	Clause 5.6
- Cold (operational)	Pass	Clause 5.7
- Damp heat. Cyclic (operational)	Pass	Clause 5.8
Damp heat, steady state (endurance) Durability of operational	Pass	Clause 5.9
reliability, humidity resistance		
- Damp heat, cyclic (operational)	Pass	Clause 5.8
- Damp heat, steady state (endurance)	Pass	Clause 5.9
- Damp heat, cyclic (endurance)	Pass	Clause 5.10
Durability of operational reliability, corrosion resistance		
- Sulphur dioxide (SO2) corrosion (endurance)	Pass	Clause 5.11
Durability of operational reliability, shock and vibration resistance		
- Shock (operational)	Pass	Clause 5.12
- Impact (operational)	Pass	Clause 5.13
- Vibration, sinusoidal (operational)	Pass	Clause 5.14
- Vibration, sinusoidal (endurance)	Pass	Clause 5.15
Durability of operational reliability, electrical stability	1 400	0.0000 0.10
- Electromagnetic compatibility (EMC), immunity	Pass	Clause 5.16
(operational)	. 400	0.00000.10
Durability of operational reliability, resistance to ingress		
- Enclosure protection	Pass	Clause 5.17

The performance of the product identified above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Martin Streetz

Quality Assurance Manager

Telephone: +44 (0)20 8743 8880

Facsimile: +44 (0)20 8740 4200

Date and Place of Issue: London, 17/10/2013 **Document No:** 0786-CPD-20338

Issue:

European Safety Systems Ltd Company Registration No. 2763350 Registered Office: Impress House Mansell Road, London, UK, W3 7QH, UK

E-mail: sales@e2s.com www.e2s.com